

BILL NO. 05-1**1st Reading 1/24/05****2nd Reading 3/07/05****CITY OF NEWARK
DELAWARE****ORDINANCE NO. 05 - 2****An Ordinance Amending Chapter 25, Sewers,
Code of the City of Newark, Delaware, By
Revising Industrial Discharge Limits for
Wilmington's Wastewater Treatment Plant**

THE COUNCIL OF THE CITY OF NEWARK HEREBY ORDAINS:

That Chapter 25, Sewers, Code of the City of Newark, Delaware, be and hereby is amended in the following respect:

AMENDMENT 1. Amend Section 25-27, Maximum constituents, Subsection (a), *Limitations of concentrations*, by deleting it in its entirety and substituting in lieu thereof the following new language:“(a) *Limitations of concentrations.* The concentration in wastewater of any of the following constituents shall be limited to the following (see also Section 25-28):

	<u>CONTRIBUTORY INDUSTRIAL USER 30 DAY AVG. MG/L</u>	<u>WILMINGTON POTW MAXIMUM ALLOWABLE INDUSTRIAL LOADING LBS/DAY</u>
Arsenic	0.09	8.18
Cadmium	0.07	9.15
Chromium, total	4.00	177.66
Copper	0.91	108.39
Lead	1.94	175.97
Mercury	0.0057	0.42
Nickel	1.00	206.40
Selenium	0.65	67.46
Zinc	3.49	422.37
Ammonia as Nitrogen	35.00	4950
Cyanide	0.49	79.59
Phenolics, total	10.00	6780
BOD	500.00	118991
Suspended Solids	500.00	72268

MOTION for Acceptance as First Reading on January 24, 2005

By Council Member Athey.

Second Reading and Final Passage on March 7, 2005.

Vote: 6 to 0.

Vance A. Thurk III

Mayor

Attest:

Dorothy L. Garblach

City Secretary

Approved as to Legality & Form:

Roger A. Akin

City Solicitor